



LIETUVOS
NACIONALINIS
AKREDITACIJOS
BIURAS

PRODUKTŲ SERTIFIKAVIMAS
ISO/IEC 17065 Nr.LA.03.001

UAB „ELEKTROTECHNINIŲ GAMINIŲ SERTIFIKAVIMO CENTRAS“ (EGSC)

Kaukysos g. 18, LT -11342 Vilnius
Lietuvos Respublika

Atitikties sertifikatas

Certificate of Conformity

Nr. LS801.B14017



**This certificate of conformity gives a right
to mark production with the mark of conformity:**

Issued to UAB „AMALVA”,
Ozo street 10, LT-08200 Vilnius, Lithuania.

This certificate of conformity indicates that product

air handling unit

type (model) series domekt

REGO – X–X X – X X X XX/XX – X – X

RECU – X–X X – X X X XX/XX – X – X

(for designation of models see page 2)

manufactured by

UAB „AMALVA”,
Ozo street 10, LT-08200 Vilnius, Lithuania

is in conformity with the requirements of the standard (-s):

LST EN 60335-1:2012 (EN 60335-1:2012).

The certificate of conformity is issued on the basis:

EGSC test report No.AFD.01.2434-14 dated 07.10.2014 and factory inspection report dated 28.10.2014.

Expiry date: 24th November 2017

Issue date: 24th November 2014

Director

V. Keršys





LIETUVOS
NACIONALINIS
AKREDITACIJOS
BIURAS

PRODUKTŲ SERTIFIKAVIMAS
ISO/IEC 17065 Nr. LA.03.001

UAB „ELEKTROTECHNINIŲ GAMINIŲ SERTIFIKAVIMO CENTRAS“ (EGSC)

Kaukysos g. 18, LT -11342 Vilnius
Lietuvos Respublika

2 page Certificate of conformity Nr.LS801.B14017 dated 24.11.2014

series domekt

XXXX - X - X X - X X X XX/XX - X - X

Filter class (M5 or F7)

Controller type C4

Motor type: EC-electronically commutated
AC-alternating current

Silencer (indicated if used), VPPS

With a kitchen hood (indicated if used), K

By-pass (indicated if used), B

Electric air heater

Version: V- vertical, P- flat

Unit size (shows nominal air flow)

Type: REGO – with rotary heat exchanger
RECU – with plate heat exchanger

Director



V. Keršys